## TECHNICAL SPECIFICATIONS THE COLUMNS ARE DESIGNED TO WITHSTAND WIND SPEED OF 35M PER SECOND, TOPOGRAPHY, GROUND ROUGHNESS & STATISTICAL FACTOR OF 1.0. - COLUMNS ARE MANUFACTURED IN COMPLIANCE TO BRITISH STANDARD BS EN 40. (BY OTHERS) - MATERIALS USED FOR LIGHTING COLUMNS ARE 125 COMPLIANCE TO BS EN 10025 S275 /JIS G3101 SS400. LIGHTING COLUMNS ARE LONGITUDINALLY SEAM WELDED CONFORM TO BS 5135 BY AUTOMATIC CONTINUOUS METAL INERT GAS (MIG) PROCESS. SPIGOT SIZE COLUMNS ARE ANTI-CORRODED BY HOT-DIP GALVANIZED, COMPLIANCE TO GALVANIZING STANDARD BS EN ISO 1461 Ø48 SERVICE DOOR DIMENSIONS ARE GIVEN AS A GUIDE ONLY. THE ENGINEER MUST SATISFY HIMSELF THAT DIMENSIONS GIVEN ARE ADEQUATE FOR THE INSTALLATION OF THE DOUBLE SHORT ARM REQUIRED CONTROL GEAR. ALL DIMENSIONS ARE IN (mm), UNLESS OTHERWISE SPECIFIED. NOMINAL MOUNTING HEIGHT **DOUBLE** OCTAGONAL POLE SLOT BASE BOARD HINGED NON-HYGROSCOPIC MATERIAL (BY BUYER) 450 <u>N</u> EARTHING STAINLESS STEEL DOOR COVER LOCKING BOLT SECTION A-A SERVICE DOOR DETAIL **DOUBLE** SLOT HINGED SERVICE DOOR NOS. 30x50mm ONGATED HOLES. 260 C-C 610 LOCK NUT ₹X Χſ **WASHER** SQ. GROUND LEVEL LEVELING NUT *W* ?</?</ 335 ø25 4 SECTION X-X J-BOLT CLIENT: DRAW NO : 10M/SLC/DSA/FM/R0 GALVAPOLE INDUSTRIES SDN. BHD.



9, JALAN KECAPI 33/2, ELITE INDUSTRIAL ESTATE JALAN BUKIT KEMUNING, 40350 SHAH ALAM, SELANGOR MALAYSIA

Tel: 603-51213300 Fax: 603-51212828 Website: www.galvapole.com Email: sales@galvapole.com

			2	
,	PROJECT : -		FILE NAME : SLC STD ISO	
	DATE: 17-03-2010	DRAWN BY : A.D	CHECKED BY : CCC	SCALE : N.T.S
DRAWING TITLE :			APPROVED BY : CCC	A4 SIZE
			THIS DRAWING IS THE PROPERTY OF GALVAPOLE INDUSTRIES SDN. BHD. AND MUST NOT BE REPRODUCED WITHOUT THEIR PRIOR CONSENT IN WRITING.	